

MADBURY TREATED SURFACE WATER
 PFAS SAMPLE RESULTS
 (UNITS: PARTS PER TRILLION (PPT))

SAMPLE LOCATION	NHDES MCL	-	-	-	-	-	-	-	-	-	-	-	-	-	18	-	11	-
	COLLECTION DATE	6:2 FTS	8:2 FTS	EtFOSA	EtFOSE	MEFOSA	MEFOSE	PFBS	PFBA	PFDS	PFDA	PFDoA	PFHpS	PFHpA	PFHxS	PFHxA	PFNA	PFOSA
Treatment Plant Finished	11/9/2016	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Treatment Plant Finished	4/27/2017	ND	ND	ND	ND	ND	ND	ND	18 J	ND	ND	ND	ND	ND	ND	ND	ND	ND
Treatment Plant Finished	10/31/2017	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Treatment Plant Finished	4/26/2018	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Treatment Plant Finished	10/24/2018	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Treatment Plant Finished	11/28/2018	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Treatment Plant Finished	4/29/2019	2.2 J	ND	NA	NA	NA	NA	1.1 J	1.0 J	ND	0.8 J	ND	ND	1.7 J	0.9 J	1.7 J	0.9 J	ND
Treatment Plant Finished	7/31/2019	ND	ND	NA	NA	NA	NA	0.6 J	3.6	ND	ND	ND	ND	0.8 J	ND	1.1 J	ND	ND
Treatment Plant Finished	10/25/2019	ND	ND	ND	NA	ND	NA	1.0 J	34	ND	ND	ND	ND	1.2 J	ND	1.3 J	ND	ND
Treatment Plant Finished	1/24/2020	ND	ND	ND	NA	ND	NA	0.7 J	11 J	ND	ND	ND	ND	0.8 J	0.4 J	0.8 J	ND	0.4 J
Treatment Plant Finished	4/29/2020	ND	ND	NA	NA	NA	NA	ND	22	ND	ND	ND	ND	0.4 J	ND	0.3 J	0.3 J	ND
Treatment Plant Finished	7/21/2020	NA	NA	NA	NA	NA	NA	0.5 J	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Treatment Plant Finished	10/30/2020	1.9 J	ND	NA	NA	NA	NA	1.1 J	1.8 J	NA	ND	ND	ND	1.1 J	0.4 J	2.9	0.5 J	NA
Treatment Plant Finished	1/28/2021	0.9 J	ND	NA	NA	NA	NA	0.9 J	1.2 J	NA	ND	ND	ND	1.4 J	0.6 J	1.1 J	ND	NA
Treatment Plant Finished	4/20/2021	0.9 J	ND	NA	NA	NA	NA	0.6 J	4.9	NA	ND	ND	ND	0.6 J	0.4 J	0.6 J	ND	NA
Treatment Plant Finished	8/2/2021	1.4 J	ND	NA	NA	NA	NA	1.1 J	3.1	NA	ND	ND	ND	1.6 J	0.6 J	1.3 J	0.6 J	NA
Treatment Plant Finished	11/12/2021	1.3 J	ND	NA	NA	NA	NA	1.2 J	3.4	NA	ND	ND	ND	1.6 J	ND	1.6 J	ND	NA
Treatment Plant Finished	3/1/2022	ND	ND	NA	NA	NA	NA	ND	2.7	NA	ND	ND	ND	ND	ND	ND	ND	NA
Treatment Plant Finished	6/10/2022	ND	ND	NA	NA	NA	NA	0.8 J	1.5 J	NA	ND	ND	ND	1.2 J	0.7 J	1.1 J	ND	NA
Treatment Plant Finished	9/2/2022	ND	ND	NA	NA	NA	NA	ND	ND	NA	ND	ND	ND	ND	ND	ND	ND	NA
Treatment Plant Finished	11/10/2022	ND	ND	NA	NA	NA	NA	ND	6.3	NA	ND	ND	ND	ND	ND	ND	ND	NA

ND = Not detected above Method Detection Limit (MDL)

NA = Not analyzed

J = Estimated value between the Method Detection Limit (MDL) and the Reportable Detection Limit (RDL)

MADBURY TREATED SURFACE WATER
 PFAS SAMPLE RESULTS
 (UNITS: PARTS PER TRILLION (PPT))

SAMPLE LOCATION	NHDES MCL	15	12	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	COLLECTION DATE	PFOS	PFOA	PFPeA	PFTeDA	PFTrDA	PFUnA	PFMPA	PFMBA	PFEESA	NFDHA	4:2 FTS	PFPeS	HFPO-DA	ADONA	11CI-PF3OUds	9CI-PF3ONS
Treatment Plant Finished	11/9/2016	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Treatment Plant Finished	4/27/2017	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Treatment Plant Finished	10/31/2017	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Treatment Plant Finished	4/26/2018	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Treatment Plant Finished	10/24/2018	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Treatment Plant Finished	11/28/2018	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Treatment Plant Finished	4/29/2019	1.2 J	2.8	1.7 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Treatment Plant Finished	7/31/2019	ND	2.1	0.9 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Treatment Plant Finished	10/25/2019	ND	2.0	1.3 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Treatment Plant Finished	1/24/2020	0.9 J	1.7 J	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Treatment Plant Finished	4/29/2020	ND	0.8	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Treatment Plant Finished	7/21/2020	0.6 J	1.3 J	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Treatment Plant Finished	10/30/2020	1.1 J	2.6	1.9 J	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Treatment Plant Finished	1/28/2021	ND	1.6 J	1.4 J	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Treatment Plant Finished	4/20/2021	ND	1.3 J	0.7 J	NA	NA	0.3 J	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Treatment Plant Finished	8/2/2021	1.5 J	3.0	1.7 J	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Treatment Plant Finished	11/12/2021	ND	2.4	1.8 J	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Treatment Plant Finished	3/1/2022	ND	ND	ND	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Treatment Plant Finished	6/10/2022	1.1 J	2.4	1.0 J	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Treatment Plant Finished	9/2/2022	ND	3.4	ND	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Treatment Plant Finished	11/10/2022	ND	2.5	ND	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

ND = Not detected above Method Detection Limit (MDL)

NA = Not analyzed

J = Estimated value between the Method Detection Limit (MDL) and the Reportable Detection Limit (RDL)

MADBURY WELL 2
 PFAS SAMPLE RESULTS
 (UNITS: PARTS PER TRILLION (PPT))

SAMPLE LOCATION	COLLECTION DATE	6:2 FTS	8:2 FTS	EtFOSA	EtFOSE	MEFOSA	MEFOSE	PFBS	PFBA	PFDS	PFDA	PFDoA	PFHpS	PFHpA	PFHxS	PFHxA	PFNA	PFOSA
Madbury Well 2	5/16/2014	NA	NA	NA	NA	NA	NA	ND	NA	NA	NA	NA	NA	ND	ND	NA	ND	NA
Madbury Well 2	11/9/2016	ND	ND	ND	ND	ND	ND	3.8 J	ND	ND	ND	ND	ND	ND	4.2 J	ND	ND	ND
Madbury Well 2	10/31/2017	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 2	4/26/2018	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 2	10/24/2018	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 2	11/28/2018	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 2	4/29/2019	0.8 J	ND	NA	NA	NA	NA	2.8	2.4	ND	ND	ND	ND	1.6 J	1.3 J	3.3	ND	ND
Madbury Well 2	7/31/2019	ND	ND	NA	NA	NA	NA	1.1 J	0.6 J	ND	ND	ND	ND	ND	ND	0.7 J	ND	ND
Madbury Well 2	10/25/2019	ND	ND	ND	NA	ND	NA	2.3	1.5 J	ND	ND	ND	ND	0.9 J	ND	2.1	ND	ND
Madbury Well 2	1/24/2020	ND	ND	ND	NA	ND	NA	1.8 J	1.5 J	ND	ND	ND	ND	0.9 J	0.8 J	1.4 J	ND	ND
Madbury Well 2	4/29/2020	ND	ND	NA	NA	NA	NA	1.1 J	0.7 J	ND	ND	ND	ND	0.2 J	ND	0.3 J	ND	ND
Madbury Well 2	7/21/2020	NA	NA	NA	NA	NA	NA	1.1 J	0.9 J	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 2	10/30/2020	ND	ND	NA	NA	NA	NA	1.7 J	1.5 J	NA	ND	ND	ND	0.7 J	0.7 J	1.5 J	ND	NA
Madbury Well 2	1/28/2021	ND	ND	NA	NA	NA	NA	1.9	1.9	NA	ND	ND	ND	1.1 J	1.0 J	1.6 J	ND	NA
Madbury Well 2	4/20/2021	ND	ND	NA	NA	NA	NA	1.4 J	0.7 J	NA	ND	ND	ND	0.4 J	0.6 J	0.6 J	ND	NA
Madbury Well 2	8/2/2021	ND	ND	NA	NA	NA	NA	1.7 J	1.4 J	NA	ND	ND	ND	0.7 J	0.6 J	1.3 J	ND	NA
Madbury Well 2	11/12/2021	ND	ND	NA	NA	NA	NA	2.2	2.1	NA	ND	ND	ND	1.1 J	0.797 J	2.0 J	ND	NA
Madbury Well 2	3/1/2022	ND	ND	NA	NA	NA	NA	4.0	2.4	NA	ND	ND	ND	ND	ND	3.3	ND	NA
Madbury Well 2	6/10/2022	ND	ND	NA	NA	NA	NA	1.9 J	2.2	NA	ND	ND	ND	1.3 J	0.9 J	1.8 J	ND	NA
Madbury Well 2	9/2/2022	ND	ND	NA	NA	NA	NA	ND	ND	NA	ND	ND	ND	ND	ND	ND	ND	NA
Madbury Well 2	11/10/2022	ND	ND	NA	NA	NA	NA	ND	ND	NA	ND	ND	ND	ND	ND	ND	ND	NA

ND = Not detected above Method Detection Limit (MDL)

NA = Not analyzed

J = Estimated value between the Method Detection Limit (MDL) and the Reportable Detection Limit (RDL)

MADBURY WELL 2
 PFAS SAMPLE RESULTS
 (UNITS: PARTS PER TRILLION (PPT))

SAMPLE LOCATION	COLLECTION DATE	PFOS	PFOA	PFPeA	PFTeDA	PFTrDA	PFUnA	PFMPA	PFMBA	PFEESA	NFDHA	4:2 FTS	PFPeS	HFPO-DA	ADONA	11C-PF3OUds	9C-PF3ONS
Madbury Well 2	5/16/2014	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 2	11/9/2016	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 2	10/31/2017	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 2	4/26/2018	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 2	10/24/2018	ND	9.2 J	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 2	11/28/2018	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 2	4/29/2019	1.5 J	4.2	3.1	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 2	7/31/2019	ND	1.1 J	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 2	10/25/2019	ND	2.9	1.9 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 2	1/24/2020	1.6 J	3.0	1.0 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 2	4/29/2020	0.7 J	0.6	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 2	7/21/2020	ND	1.1 J	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 2	10/30/2020	1.4 J	2.3	1.6 J	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 2	1/28/2021	1.2 J	2.7	1.9	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 2	4/20/2021	1.4 J	1.3 J	0.6 J	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 2	8/2/2021	1.1 J	2.4	1.3 J	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 2	11/12/2021	1.3 J	4.0	2.2	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 2	3/1/2022	ND	5.7	2.5	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 2	6/10/2022	1.3 J	3.8	2.0 J	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 2	9/2/2022	ND	2.4	ND	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 2	11/10/2022	ND	2.1	ND	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

ND = Not detected above Method Detection Limit (MDL)

NA = Not analyzed

J = Estimated value between the Method Detection Limit (MDL) and the Reportable Detection Limit (RDL)

MADBURY WELL 3
 PFAS SAMPLE RESULTS
 (UNITS: PARTS PER TRILLION (PPT))

SAMPLE LOCATION	NHDES MCL	-	-	-	-	-	-	-	-	-	-	-	-	18	-	11	-	
	COLLECTION DATE	6:2 FTS	8:2 FTS	EtFOSA	EtFOSE	MEFOSA	MEFOSE	PFBS	PFBA	PFDS	PFDA	PFDoA	PFHpS	PFHpA	PFHxS	PFHxA	PFNA	PFOSA
Madbury Well 3	5/16/2014	NA	NA	NA	NA	NA	NA	ND	NA	NA	NA	NA	NA	ND	ND	NA	ND	NA
Madbury Well 3	6/9/2016	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 3	11/9/2016	ND	ND	ND	ND	ND	ND	3.7 J	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 3	4/27/2017	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 3	10/31/2017	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 3	4/26/2018	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 3	10/24/2018	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 3	4/29/2019	1.0 J	ND	NA	NA	NA	NA	1.8 J	2.1	ND	ND	ND	ND	1.4 J	1.2 J	1.8 J	0.7 J	ND
Madbury Well 3	7/31/2019	ND	ND	NA	NA	NA	NA	1.1 J	1.2 J	ND	ND	ND	ND	0.6 J	0.4 J	1.2 J	ND	ND
Madbury Well 3	10/25/2019	ND	ND	ND	NA	ND	NA	1.3 J	1.6 J	ND	ND	ND	ND	1.2 J	ND	2.1	ND	ND
Madbury Well 3	1/24/2020	ND	ND	ND	NA	ND	NA	1.5 J	1.6 J	ND	ND	ND	ND	1.2 J	0.9 J	1.8 J	ND	0.6 J
Madbury Well 3	4/29/2020	ND	ND	NA	NA	NA	NA	1.1 J	1.0 J	ND	ND	ND	ND	0.5	0.5 J	0.7	ND	ND
Madbury Well 3	7/21/2020	NA	NA	NA	NA	NA	NA	0.9 J	1.1 J	ND	ND	ND	ND	0.5 J	ND	0.8 J	ND	ND
Madbury Well 3	10/30/2020	1.3 J	ND	NA	NA	NA	NA	1.7 J	1.7 J	NA	ND	ND	ND	1.4 J	0.9 J	2.6	ND	NA
Madbury Well 3	1/28/2021	ND	ND	NA	NA	NA	NA	1.8 J	1.1 J	NA	ND	ND	ND	1.1 J	0.9 J	1.3 J	ND	NA
Madbury Well 3	4/20/2021	ND	ND	NA	NA	NA	NA	1.9	1.3 J	NA	ND	ND	ND	1.0 J	0.9 J	1.5 J	ND	NA
Madbury Well 3	8/2/2021	ND	ND	NA	NA	NA	NA	2.5	1.7 J	NA	ND	ND	ND	1.4 J	1.4 J	2.2	ND	NA
Madbury Well 3	11/12/2021	ND	ND	NA	NA	NA	NA	1.6 J	2.3	NA	ND	ND	ND	1.6 J	ND	3.6	ND	NA
Madbury Well 3	3/1/2022	ND	ND	NA	NA	NA	NA	ND	2.3	NA	ND	ND	ND	ND	ND	2.1	ND	NA
Madbury Well 3	6/10/2022	ND	ND	NA	NA	NA	NA	1.7 J	2.0 J	NA	ND	ND	ND	1.3 J	0.8 J	2.6	ND	NA
Madbury Well 3	8/22/2022	ND	ND	NA	NA	NA	NA	2.2	ND	NA	ND	ND	ND	ND	ND	2.4	ND	NA

ND = Not detected above Method Detection Limit (MDL)

NA = Not analyzed

J = Estimated value between the Method Detection Limit (MDL) and the Reportable Detection Limit (RDL)

MADBURY WELL 3
 PFAS SAMPLE RESULTS
 (UNITS: PARTS PER TRILLION (PPT))

SAMPLE LOCATION	NHDES MCL	15	12	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	COLLECTION DATE	PFOS	PFOA	PFPeA	PFTeDA	PFTrDA	PFUnA	PFMPA	PFMBA	PFEESA	NFDHA	4:2 FTS	PFPeS	HFPO-DA	ADONA	11CI-PF3OUds	9CI-PF3ONS
Madbury Well 3	5/16/2014	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 3	6/9/2016	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 3	11/9/2016	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 3	4/27/2017	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 3	10/31/2017	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 3	4/26/2018	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 3	10/24/2018	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 3	4/29/2019	1.5 J	2.6	1.7 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 3	7/31/2019	0.7 J	1.8 J	1.5 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 3	10/25/2019	ND	2.7	2.4	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 3	1/24/2020	1.6 J	2.7	1.5 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 3	4/29/2020	0.6 J	1.4	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 3	7/21/2020	0.6 J	1.5 J	0.9 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 3	10/30/2020	1.4 J	2.7	2.7	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 3	1/28/2021	1.5 J	2.7	1.4 J	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 3	4/20/2021	1.3 J	2.5	1.6 J	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 3	8/2/2021	0.9 J	3.4	2.5	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 3	11/12/2021	1.4 J	3.7	3.7	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 3	3/1/2022	ND	2.8	2.7	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 3	6/10/2022	1.3 J	3.0	2.9	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 3	8/22/2022	ND	3.9	2.2	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

ND = Not detected above Method Detection Limit (MDL)

NA = Not analyzed

J = Estimated value between the Method Detection Limit (MDL) and the Reportable Detection Limit (RDL)

MADBURY WELL 4 and 4R
 PFAS SAMPLE RESULTS
 (UNITS: PARTS PER TRILLION (PPT))

SAMPLE LOCATION	NHDES MCL	-	-	-	-	-	-	-	-	-	-	-	-	18	-	11	-	
	COLLECTION DATE	6:2 FTS	8:2 FTS	EtFOSA	EtFOSE	MEFOSA	MEFOSE	PFBS	PFBA	PFDS	PFDA	PFDoA	PFHpS	PFHpA	PFHxS	PFHxA	PFNA	PFOSA
Madbury Well 4	5/16/2014	NA	NA	NA	NA	NA	NA	ND	NA	NA	NA	NA	NA	ND	ND	NA	ND	NA
Madbury Well 4	11/9/2016	ND	ND	ND	ND	ND	ND	3.8 J	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 4	4/27/2017	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 4	10/31/2017	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 4	4/26/2018	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 4	10/24/2018	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 4	4/29/2019	1.7 J	ND	NA	NA	NA	NA	2.1	1.2 J	ND	ND	ND	ND	1.0 J	1.3 J	1.4 J	ND	ND
Madbury Well 4	7/31/2019	ND	ND	NA	NA	NA	NA	1.8 J	ND	ND	ND	ND	ND	ND	0.5 J	ND	ND	ND
Madbury Well 4	10/25/2019	ND	ND	ND	NA	ND	NA	2.2	0.5 J	ND	ND	ND	ND	ND	ND	0.7 J	ND	ND
Madbury Well 4	1/24/2020	ND	ND	ND	NA	ND	NA	2.2	1.2 J	ND	ND	ND	ND	0.6 J	0.7 J	0.9 J	ND	ND
Madbury Well 4	4/29/2020	ND	ND	NA	NA	NA	NA	1.7 J	0.5 J	ND	ND	ND	ND	0.3 J	0.6 J	0.5 J	ND	ND
Madbury Well 4	7/21/2020	NA	NA	NA	NA	NA	NA	1.5 J	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 4	10/30/2020	ND	ND	NA	NA	NA	NA	2.1	0.6 J	NA	ND	ND	ND	1.0 J	0.6 J	1.4 J	ND	NA
Madbury Well 4	2/18/2021	ND	ND	NA	NA	NA	NA	0.5 J	0.6 J	NA	ND	ND	ND	ND	ND	0.3 J	ND	NA
Madbury Well 4	4/20/2021	ND	ND	NA	NA	NA	NA	0.9 J	0.3 J	NA	ND	ND	ND	ND	ND	0.6 J	ND	NA
Madbury Well 4	8/2/2021	ND	ND	NA	NA	NA	NA	1.9 J	ND	NA	ND	ND	ND	ND	0.6 J	0.7 J	ND	NA
Madbury Well 4	11/12/2021	ND	ND	NA	NA	NA	NA	3.2	ND	NA	ND	ND	ND	ND	0.7 J	0.7 J	ND	NA
Madbury Well 4	3/1/2022	ND	ND	NA	NA	NA	NA	3.6	ND	NA	ND	ND	ND	ND	ND	ND	ND	NA
Madbury Well 4R	9/2/2022	ND	ND	NA	NA	NA	NA	3.2	ND	NA	ND	ND	ND	ND	ND	ND	ND	NA
Madbury Well 4R	11/10/2022	ND	ND	NA	NA	NA	NA	2.3	ND	NA	ND	ND	ND	ND	ND	ND	ND	NA

ND = Not detected above Method Detection Limit (MDL)

NA = Not analyzed

J = Estimated value between the Method Detection Limit (MDL) and the Reportable Detection Limit (RDL)

MADBURY WELL 4 and 4R
 PFAS SAMPLE RESULTS
 (UNITS: PARTS PER TRILLION (PPT))

SAMPLE LOCATION	NHDES MCL	15	12	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	COLLECTION DATE	PFOS	PFOA	PFPeA	PFTeDA	PFTrDA	PFUnA	PFMPA	PFMBA	PFEESA	NFDHA	4:2 FTS	PFPeS	HFPO-DA	ADONA	11CI-PF3OUds	9CI-PF3ONS
Madbury Well 4	5/16/2014	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 4	11/9/2016	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 4	4/27/2017	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 4	10/31/2017	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 4	4/26/2018	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 4	10/24/2018	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 4	4/29/2019	0.9 J	2.0	1.2 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 4	7/31/2019	ND	1.2 J	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 4	10/25/2019	ND	1.3 J	0.6 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 4	1/24/2020	0.9 J	2.1	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 4	4/29/2020	ND	0.9	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 4	7/21/2020	ND	1.0 J	0.7 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Madbury Well 4	10/30/2020	1.2 J	3.6	1.3 J	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 4	2/18/2021	ND	0.5 J	0.3 J	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 4	4/20/2021	ND	0.8 J	0.6 J	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 4	8/2/2021	ND	1.4 J	0.6 J	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 4	11/12/2021	ND	1.5 J	0.7 J	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 4	3/1/2022	ND	ND	ND	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 4R	9/2/2022	ND	ND	ND	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 4R	11/10/2022	ND	ND	ND	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

ND = Not detected above Method Detection Limit (MDL)

NA = Not analyzed

J = Estimated value between the Method Detection Limit (MDL) and the Reportable Detection Limit (RDL)

MADBURY WELL 5
 PFAS SAMPLE RESULTS
 (UNITS: PARTS PER TRILLION (PPT))

NHDES MCL		-	-	-	-	-	-	-	-	-	-	-	-	-	18	-	11	-
SAMPLE LOCATION	COLLECTION DATE	6:2 FTS	8:2 FTS	EtFOSA	EtFOSE	MEFOSA	MEFOSE	PFBS	PFBA	PFDS	PFDA	PFDoA	PFHpS	PFHpA	PFHxS	PFHxA	PFNA	PFOSA
Madbury Well 5	9/2/2022	ND	ND	NA	NA	NA	NA	6.4	ND	NA	ND	ND	ND	ND	ND	2.8	ND	NA
Madbury Well 5	11/10/2022	ND	ND	NA	NA	NA	NA	4.4	ND	NA	ND	ND	ND	ND	ND	2.2	ND	NA

ND = Not detected above Method Detection Limit (MDL)

NA = Not analyzed

J = Estimated value between the Method Detection Limit (MDL) and the Reportable Detection Limit (RDL)

MADBURY WELL 5
 PFAS SAMPLE RESULTS
 (UNITS: PARTS PER TRILLION (PPT))

NHDES MCL		15	12	-	-	-	-	-	-	-	-	-	-	-	-	-	-
SAMPLE LOCATION	COLLECTION DATE	PFOS	PFOA	PFPeA	PFTeDA	PFTrDA	PFUnA	PFMPA	PFMBA	PFEESA	NFDHA	4:2 FTS	PFPeS	HFPO-DA	ADONA	11Cl- PF3OUdS	9Cl-PF3ONS
Madbury Well 5	9/2/2022	ND	4.5	2.8	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Madbury Well 5	11/10/2022	ND	2.7	ND	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

ND = Not detected above Method Detection Limit (MDL)

NA = Not analyzed

J = Estimated value between the Method Detection Limit (MDL) and the Reportable Detection Limit (RDL)

GREENLAND WELL
 PFAS SAMPLE RESULTS
 (UNITS: PARTS PER TRILLION (PPT))

NHDES MCL		-	-	-	-	-	-	-	-	-	-	-	-	-	18	-	11	-
SAMPLE LOCATION	COLLECTION DATE	6:2 FTS	8:2 FTS	EtFOSA	EtFOSE	MEFOSA	MEFOSE	PFBS	PFBA	PFDS	PFDA	PFDoA	PFHpS	PFHpA	PFHxS	PFHxA	PFNA	PFOSA
Greenland Well	5/16/2014	NA	NA	NA	NA	NA	NA	ND	NA	NA	NA	NA	NA	ND	ND	NA	ND	NA
Greenland Well	7/21/2014	NA	NA	NA	NA	NA	NA	ND	NA	NA	NA	NA	NA	ND	ND	NA	ND	NA
Greenland Well	2/10/2015	NA	NA	NA	NA	NA	NA	ND	NA	NA	NA	NA	NA	ND	ND	NA	ND	NA
Greenland Well	8/1/2016	ND	ND	ND	ND	ND	ND	3.3 J	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Greenland Well	11/17/2016	7.0 J	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	6.1 J	ND	ND	ND
Greenland Well	11/17/2016	ND	ND	ND	ND	ND	ND	3.5 J	ND	ND	ND	ND	ND	ND	5.8 J	ND	ND	ND
Greenland Well	4/27/2017	ND	ND	ND	ND	ND	ND	6.2 J	ND	ND	ND	ND	ND	ND	6.0 J	3.3 J	ND	ND
Greenland Well	10/31/2017	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Greenland Well	4/26/2018	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Greenland Well	10/24/2018	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	8.5 J	ND	ND
Greenland Well	11/28/2018	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	5.8 J	ND	ND
Greenland Well	4/29/2019	1.0 J	ND	NA	NA	NA	NA	2.3	2.8	ND	ND	ND	ND	3.1	2.1	5.6	0.8 J	ND
Greenland Well	4/29/2019	0.8 J	ND	NA	NA	NA	NA	2.3	2.7	ND	ND	ND	ND	3.0	1.9 J	5.3	0.7 J	ND
Greenland Well	7/31/2019	ND	ND	NA	NA	NA	NA	1.6 J	1.5 J	ND	ND	ND	ND	1.3 J	1.8 J	3.2	ND	ND
Greenland Well	10/25/2019	ND	ND	ND	NA	ND	NA	1.7 J	1.4 J	ND	ND	ND	ND	1.2 J	1.7 J	2.7	ND	ND
Greenland Well	1/23/2020	ND	ND	ND	NA	ND	NA	2.8	2.0 J	ND	ND	ND	ND	1.6 J	2.5	3.5	ND	ND
Greenland Well	4/29/2020	ND	ND	NA	NA	NA	NA	1.3 J	1.7 J	ND	ND	ND	ND	1.6	0.9 J	2.5	0.2 J	ND
Greenland Well	7/22/2020	NA	NA	NA	NA	NA	NA	1.6 J	1.5 J	ND	ND	ND	ND	1.2 J	1.5 J	2.3	ND	ND
Greenland Well	10/30/2020	0.9 J	ND	NA	NA	NA	NA	2.7	1.7 J	NA	ND	ND	ND	1.6 J	2.5	3.9	ND	NA
Greenland Well	1/28/2021	ND	ND	NA	NA	NA	NA	2.6	1.7 J	NA	ND	ND	ND	1.6 J	2.1	4.0	0.4 J	NA
Greenland Well	4/20/2021	ND	ND	NA	NA	NA	NA	3.2	1.9 J	NA	ND	ND	ND	1.6 J	2.4	4.3	ND	NA
Greenland Well	8/3/2021	ND	ND	NA	NA	NA	NA	2.6	2.0 J	NA	ND	ND	ND	1.7 J	2.2	4.3	ND	NA
Greenland Well	11/12/2021	ND	ND	NA	NA	NA	NA	3.6	2.4	NA	ND	ND	ND	1.9 J	2.6	5.2	ND	NA
Greenland Well	3/1/2022	ND	ND	NA	NA	NA	NA	ND	2.7	NA	ND	ND	ND	3.1	ND	5.2	ND	NA
Greenland Well	6/10/2022	ND	ND	NA	NA	NA	NA	3.1	2.1	NA	ND	ND	ND	2.3	1.9 J	4.5	ND	NA
Greenland Well	9/1/2022	ND	ND	NA	NA	NA	NA	2.8	2.3	NA	ND	ND	ND	2.5	4.4	ND	ND	NA
Greenland Well	11/10/2022	ND	ND	NA	NA	NA	NA	2.5	ND	NA	ND	ND	ND	ND	3.7	ND	ND	NA

ND = Not detected above Method Detection Limit (MDL)

NA = Not analyzed

J = Estimated value between the Method Detection Limit (MDL) and the Reportable Detection Limit (RDL)

GREENLAND WELL
 PFAS SAMPLE RESULTS
 (UNITS: PARTS PER TRILLION (PPT))

NHDES MCL		15	12	-	-	-	-	-	-	-	-	-	-	-	-	-	-
SAMPLE LOCATION	COLLECTION DATE	PFOS	PFOA	PFPeA	PFTeDA	PFTrDA	PFUnA	PFMPA	PFMBA	PFEESA	NFDHA	4:2 FTS	PFPeS	HFPO-DA	ADONA	11CI-PF3OUds	9CI-PF3ONS
Greenland Well	5/16/2014	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Greenland Well	7/21/2014	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Greenland Well	2/10/2015	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Greenland Well	8/1/2016	7.0 J	ND	7.1 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Greenland Well	11/17/2016	14 J	ND	4.6 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Greenland Well	11/17/2016	6.5 J	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Greenland Well	4/27/2017	3.7 J	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Greenland Well	10/31/2017	5.2 J	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Greenland Well	4/26/2018	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Greenland Well	10/24/2018	8.6 J	9.1 J	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Greenland Well	11/28/2018	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Greenland Well	4/29/2019	3.3	4.2	5.8	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Greenland Well	4/29/2019	3.1	4.2	5.5	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Greenland Well	7/31/2019	2.8	3.0	3.5	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Greenland Well	10/25/2019	3.0	2.4	1.4 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Greenland Well	1/23/2020	4.2	3.8	3.0	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Greenland Well	4/29/2020	1.2 J	2.2	3.3	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Greenland Well	7/22/2020	2.4	2.4	2.4	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Greenland Well	10/30/2020	4.4	3.8	3.7	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Greenland Well	1/28/2021	4.2	4.2	3.8	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Greenland Well	4/20/2021	4.2	4.3	3.7	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Greenland Well	8/3/2021	4.7	4.3	4.3	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Greenland Well	11/12/2021	5.7	4.9	4.9	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Greenland Well	3/1/2022	3.0	4.2	6.4	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Greenland Well	6/10/2022	3.7	4.6	4.8	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Greenland Well	9/1/2022	4.8	4.7	4.2	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Greenland Well	11/10/2022	2.7	4.0	3.1	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

ND = Not detected above Method Detection Limit (MDL)

NA = Not analyzed

J = Estimated value between the Method Detection Limit (MDL) and the Reportable Detection Limit (RDL)

PORTSMOUTH WELL #1
 PFAS SAMPLE RESULTS
 (UNITS: PARTS PER TRILLION (PPT))

SAMPLE LOCATION	NHDES MCL	-	-	-	-	-	-	-	-	-	-	-	-	18	-	11	-	
	COLLECTION DATE	6:2 FTS	8:2 FTS	EtFOSA	EtFOSE	MEFOSA	MEFOSE	PFBS	PFBA	PFDS	PFDA	PFDaA	PFHpS	PFHpA	PFHxS	PFHxA	PFNA	PFOSA
Portsmouth Well	5/20/2014	NA	NA	NA	NA	NA	NA	ND	NA	NA	NA	NA	NA	ND	ND	NA	ND	NA
Portsmouth Well	6/18/2014	NA	NA	NA	NA	NA	NA	ND	2.9 J	ND	ND	ND	NA	ND	5.8 J	ND	ND	ND
Portsmouth Well	6/25/2014	NA	NA	NA	NA	NA	NA	ND	ND	ND	ND	ND	NA	ND	4.4 J	ND	ND	ND
Portsmouth Well	6/25/2014	NA	NA	NA	NA	NA	NA	ND	ND	ND	ND	ND	NA	ND	5.1 J	ND	ND	ND
Portsmouth Well	7/2/2014	NA	NA	NA	NA	NA	NA	ND	5.8 J	ND	ND	ND	NA	ND	5.5 J	5.6 J	ND	2.5 J
Portsmouth Well	7/9/2014	NA	NA	NA	NA	NA	NA	ND	2.4 J	ND	ND	ND	NA	ND	ND	2.9 J	ND	ND
Portsmouth Well	7/16/2014	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	7.0 J	ND	ND	ND
Portsmouth Well	7/24/2014	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.8 J	ND	ND	ND
Portsmouth Well	7/24/2014	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.6 J	ND	ND	ND
Portsmouth Well	8/6/2014	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	5.2 J	ND	ND	ND
Portsmouth Well	8/21/2014	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.6 J	ND	ND	ND
Portsmouth Well	9/4/2014	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	7.3 J	3.5 J	ND	ND
Portsmouth Well	9/17/2014	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	8.4 J	ND	ND	ND
Portsmouth Well	10/16/2014	ND	ND	ND	ND	ND	ND	3.8 J	4.7 J	ND	ND	ND	ND	4.1 J	9.1 J	7.2 J	ND	ND
Portsmouth Well	11/12/2014	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.1 J	ND	ND	ND
Portsmouth Well	12/12/2014	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	5.2 J	ND	ND	ND
Portsmouth Well	1/5/2015	ND	ND	ND	ND	ND	ND	ND	4.8	ND	ND	ND	6.0 J	ND	7.9 J	6.2 J	ND	ND
Portsmouth Well	2/4/2015	ND	ND	ND	ND	ND	ND	ND	2.8 J	ND	ND	ND	ND	ND	7.6 J	5.6 J	ND	3.3 J
Portsmouth Well	3/17/2015	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.4 J	ND	ND
Portsmouth Well	3/26/2015	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	5.2 J	ND	ND
Portsmouth Well	4/23/2015	ND	ND	ND	4.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.9
Portsmouth Well	5/21/2015	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.2 J	ND	ND
Portsmouth Well	6/16/2015	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	6.4 J	ND	ND	ND
Portsmouth Well	7/16/2015	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Portsmouth Well	8/11/2015	ND	ND	ND	ND	ND	ND	4.9 J	ND	ND	ND	ND	ND	ND	7.5 J	4.9 J	ND	ND
Portsmouth Well	9/9/2015	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	7.5 J	ND	ND	ND
Portsmouth Well	10/7/2015	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	7.1 J	7.6 J	6.6 J	ND	ND
Portsmouth Well	11/4/2015	ND	ND	ND	ND	ND	ND	7.4 J	6.9 J	ND	ND	ND	ND	ND	8.5 J	7.1 J	ND	ND
Portsmouth Well	12/1/2015	ND	ND	ND	ND	ND	ND	6.8 J	10.0 J	ND	ND	ND	ND	5.3 J	11 J	8.2 J	ND	ND
Portsmouth Well	1/6/2016	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	5.7 J	9.8	6.8 J	ND	ND
Portsmouth Well	2/2/2016	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	7.1	9.9	ND	ND
Portsmouth Well	3/1/2016	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	8.2 J	12 J	ND	ND	ND
Portsmouth Well	3/29/2016	ND	ND	ND	ND	ND	ND	5.4 J	8.8 J	ND	ND	ND	ND	ND	8.7	ND	ND	ND
Portsmouth Well	4/12/2016	ND	ND	NA	NA	NA	NA	ND	ND	NA	NA	NA	ND	5.2 J	10	8.9	ND	ND
Portsmouth Well	5/26/2016	ND	ND	NA	NA	NA	NA	5.8 J	7.8 J	NA	NA	NA	ND	ND	6.9 J	ND	ND	ND
Portsmouth Well	6/23/2016	ND	ND	NA	NA	NA	NA	4.0 J	ND	NA	NA	NA	ND	ND	7.3 J	5.9 J	ND	ND
Portsmouth Well	7/19/2016	ND	ND	NA	NA	NA	NA	ND	ND	NA	NA	NA	ND	ND	8.7 J	6.1 J	ND	ND
Portsmouth Well	8/2/2016	ND	ND	NA	NA	NA	NA	4.9 J	ND	NA	NA	NA	ND	ND	9.5 J	6.3 J	ND	ND
Portsmouth Well	9/13/2016	ND	ND	NA	NA	NA	NA	3.2	ND	NA	NA	NA	ND	ND	6.3	ND	ND	ND
Portsmouth Well	11/17/2016	ND	ND	NA	NA	NA	NA	2.5 J	ND	NA	NA	NA	ND	ND	9.0 J	ND	ND	ND
Portsmouth Well	1/11/2017	ND	ND	NA	NA	NA	NA	8.4 J	ND	NA	NA	NA	ND	ND	11.0 J	12 J	ND	ND
Portsmouth Well	2/17/2017	ND	ND	NA	NA	NA	NA	2.4 J	ND	NA	NA	NA	ND	ND	5.3 J	ND	ND	ND
Portsmouth Well	3/23/2017	ND	ND	NA	NA	NA	NA	ND	ND	NA	NA	NA	ND	ND	ND	ND	ND	ND
Portsmouth Well	3/23/2017	ND	ND	NA	NA	NA	NA	ND	ND	NA	NA	NA	ND	ND	ND	ND	ND	ND
Portsmouth Well	4/19/2017	ND	ND	NA	NA	NA	NA	ND	ND	NA	NA	NA	ND	ND	9.5 J	ND	ND	ND
Portsmouth Well	6/12/2017	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.8 J	ND	ND	ND
Portsmouth Well	7/11/2017	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	11 J	ND	ND	ND

ND = Not detected above Method Detection Limit (MDL)

NA = Not analyzed

J = Estimated value between the Method Detection Limit (MDL) and the Reportable Detection Limit (RDL)

PORTSMOUTH WELL #1
 PFAS SAMPLE RESULTS
 (UNITS: PARTS PER TRILLION (PPT))

SAMPLE LOCATION	NHDES MCL	-	-	-	-	-	-	-	-	-	-	-	-	-	18	-	11	-
	COLLECTION DATE	6:2 FTS	8:2 FTS	EtFOSA	EtFOSE	MEFOSA	MEFOSE	PFBS	PFBA	PFDS	PFDA	PFDaA	PFHpS	PFHpA	PFHxS	PFHxA	PFNA	PFOSA
Portsmouth Well	8/2/2017	ND	ND	ND	ND	ND	ND	5.8 J	ND	ND	ND	ND	ND	ND	9.6 J	6.4 J	ND	ND
Portsmouth Well	9/15/2017	ND	ND	NA	NA	NA	NA	ND	ND	NA	NA	NA	ND	ND	ND	ND	ND	ND
Portsmouth Well	10/19/2017	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	9.4 J	ND	ND	ND
Portsmouth Well	11/14/2017	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Portsmouth Well	12/8/2017	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	9.2 J	ND	ND	ND
Portsmouth Well	1/9/2018	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Portsmouth Well	2/6/2018	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	8.0 J	6.8 J	ND	4.2 J
Portsmouth Well	3/6/2018	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Portsmouth Well	4/23/2018	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Portsmouth Well	5/16/2018	ND	ND	ND	ND	ND	ND	7.7 J	7.2 J	ND	ND	ND	ND	ND	ND	8.2 J	ND	ND
Portsmouth Well	6/6/2018	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Portsmouth Well	7/12/2018	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Portsmouth Well	8/16/2018	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	7.9 J	6.8 J	ND	ND
Portsmouth Well	9/20/2018	ND	ND	ND	ND	ND	ND	7.2 J	ND	ND	ND	ND	ND	ND	8.7 J	6.8 J	ND	ND
Portsmouth Well	10/18/2018	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	6.2 J	5.3 J	ND	ND
Portsmouth Well	11/7/2018	ND	ND	NA	NA	NA	NA	ND	ND	NA	NA	NA	ND	ND	ND	ND	ND	ND
Portsmouth Well	12/19/2018	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	7.9 J	5.7 J	ND	ND
Portsmouth Well	1/23/2019	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Portsmouth Well	2/20/2019	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Portsmouth Well	4/29/2019	0.8 J	ND	NA	NA	NA	NA	2.3	3.4	ND	ND	ND	2.9	5.9	4.3	0.9 J	ND	ND
Portsmouth Well	5/23/2019	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Portsmouth Well	6/12/2019	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Portsmouth Well	7/16/2019	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	6.7 J	ND	ND	ND
Portsmouth Well	7/31/2019	ND	ND	NA	NA	NA	NA	2.4	2.1	ND	ND	ND	1.9 J	4.3	3.2	ND	ND	
Portsmouth Well	8/14/2019	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Portsmouth Well	9/17/2019	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Portsmouth Well	10/15/2019	0.8 J	ND	NA	NA	NA	NA	2.2 J	2.7	ND	ND	ND	2.6	5.1	3.9	0.6 J	ND	ND
Portsmouth Well	10/25/2019	ND	ND	ND	NA	ND	NA	2.3	2.5 J	ND	ND	ND	2.4	5.1	3.9	ND	ND	ND
Portsmouth Well	11/19/2019	ND	ND	NA	NA	NA	NA	2.5	2.1	ND	ND	ND	1.7 J	4.5	3.0	ND	ND	ND
Portsmouth Well	12/4/2019	ND	ND	NA	NA	NA	NA	2.0	2.5	ND	ND	ND	2.2	4.9	3.5	ND	ND	ND
Portsmouth Well	12/4/2019	ND	ND	NA	NA	NA	NA	2.0	2.5	ND	ND	ND	2.2	4.9	3.5	ND	ND	ND
Portsmouth Well	1/21/2020	ND	ND	NA	NA	NA	NA	2.3	2.7	ND	ND	ND	2.0 J	4.7	3.3	ND	ND	ND
Portsmouth Well	1/21/2020	ND	ND	NA	NA	NA	NA	2.3	2.7	ND	ND	ND	2.0 J	4.7	3.3	ND	ND	ND
Portsmouth Well	1/23/2020	ND	ND	ND	NA	ND	NA	2.7	3.1 J	ND	ND	ND	2.7	6.0	4.3	0.5 J	0.5 J	ND
Portsmouth Well	2/18/2020	ND	ND	NA	NA	NA	NA	2.3	2.3	ND	ND	ND	2.0 J	4.6	3.2	ND	ND	ND
Portsmouth Well	3/24/2020	ND	ND	NA	NA	NA	NA	3.4 J	3.1 J	ND	ND	ND	2.4 J	5.5	3.9 J	ND	ND	ND
Portsmouth Well	4/27/2020	ND	ND	NA	NA	NA	NA	3.0 J	3.0 J	ND	ND	ND	2.6 J	5.4	3.9	ND	ND	ND
Portsmouth Well	4/29/2020	ND	ND	NA	NA	NA	NA	2.9	2.5	ND	ND	ND	1.7	4.7	2.7	0.4 J	ND	ND
Portsmouth Well	5/26/2020	ND	ND	NA	NA	NA	NA	2.8 J	2.6 J	ND	ND	ND	2.5 J	4.4	3.5 J	ND	ND	ND
Portsmouth Well	6/24/2020	ND	ND	NA	NA	NA	NA	3.8 J	2.5 J	ND	ND	ND	2.5 J	4.8	3.8 J	ND	ND	ND
Portsmouth Well	7/22/2020	NA	NA	NA	NA	NA	NA	2.6	2.1	ND	ND	ND	1.7 J	4.3	3.1	ND	ND	ND
Portsmouth Well	7/28/2020	ND	ND	NA	NA	NA	NA	4.2	3.3 J	ND	ND	ND	2.9 J	5.9	4.2	ND	ND	ND
Portsmouth Well	8/25/2020	ND	ND	NA	NA	NA	NA	3.0 J	3.0 J	ND	ND	ND	2.4 J	5.4	4.3	ND	ND	ND
Portsmouth Well	9/25/2020	ND	ND	NA	NA	NA	NA	3.4 J	3.4 J	ND	ND	ND	3.1 J	6.2	5.2	ND	ND	ND
Portsmouth Well	10/26/2020	ND	ND	NA	NA	NA	NA	2.5	3.2	ND	ND	ND	2.8	6.7	4.3	ND	ND	ND
Portsmouth Well	10/30/2020	ND	ND	NA	NA	NA	NA	2.9	3.3	NA	ND	ND	3.0	8.0	6.4	0.6 J	NA	NA
Portsmouth Well	11/16/2020	ND	ND	NA	NA	NA	NA	2.7 J	3.6 J	ND	ND	ND	3.6	7.2	5.1	ND	ND	ND

ND = Not detected above Method Detection Limit (MDL)

NA = Not analyzed

J = Estimated value between the Method Detection Limit (MDL) and the Reportable Detection Limit (RDL)

PORTSMOUTH WELL #1
 PFAS SAMPLE RESULTS
 (UNITS: PARTS PER TRILLION (PPT))

SAMPLE LOCATION	NHDES MCL COLLECTION DATE	-	-	-	-	-	-	-	-	-	-	-	-	18	-	11	-	
		6:2 FTS	8:2 FTS	EtFOSA	EtFOSE	MEFOSA	MEFOSE	PFBS	PFBA	PFDS	PFDA	PFDoA	PFHpS	PFHpA	PFHxS	PFHxA	PFNA	PFOSA
Portsmouth Well	12/14/2020	ND	ND	NA	NA	NA	NA	1.8 J	3.1 J	ND	ND	ND	ND	3.1 J	6.4	4.2	ND	ND
Portsmouth Well	1/25/2021	ND	ND	NA	NA	NA	NA	2.7 J	3.2 J	ND	ND	ND	ND	3.1 J	8.3	4.5	ND	ND
Portsmouth Well	1/28/2021	0.8 J	ND	NA	NA	NA	NA	3.0	4.1	NA	ND	ND	0.3 J	5.6	9.0	7.3	0.6 J	NA
Portsmouth Well	2/5/2021	ND	ND	NA	NA	NA	NA	1.8 J	2.6 J	ND	ND	ND	ND	2.1 J	6.2	3.3 J	ND	ND
Portsmouth Well	3/22/2021	ND	ND	NA	NA	NA	NA	3.0 J	3.8 J	ND	ND	ND	ND	3.6	6.2	5	ND	ND
Portsmouth Well	4/19/2021	ND	ND	NA	NA	NA	NA	3.1 J	2.9 J	ND	ND	ND	ND	2.7 J	6.0	3.9	ND	ND
Portsmouth Well	4/20/2021	ND	ND	NA	NA	NA	NA	3.3	3.1	NA	ND	ND	ND	3.1	6.9	5.5	0.3 J	NA
Portsmouth Well	5/24/2021	ND	ND	NA	NA	NA	NA	2.8 J	3.3 J	ND	ND	ND	ND	3.3 J	6.2	4.6	ND	ND
Portsmouth Well	6/22/2021	ND	ND	NA	NA	NA	NA	3.5 J	3.0 J	ND	ND	ND	ND	2.8 J	6.1	4.0	ND	ND
Portsmouth Well	7/20/2021	ND	ND	NA	NA	NA	NA	2.3	2.6	ND	ND	ND	ND	2.5	5.6	3.8	ND	ND
Portsmouth Well	8/3/2021	ND	ND	NA	NA	NA	NA	3.6	3.3	NA	ND	ND	ND	4.1	6.6	5.3	ND	NA
Portsmouth Well	8/24/2021	ND	ND	NA	NA	NA	NA	2 J	2.3	ND	ND	ND	ND	2.2	6.1	3.5	ND	ND
Portsmouth Well	9/22/2021	ND	ND	NA	NA	NA	NA	2.8	2.6	ND	ND	ND	ND	2.7	5.8	4	ND	ND
Portsmouth Well	10/19/2021	0.6 J	ND	NA	NA	NA	NA	2.6	3.3	ND	ND	ND	ND	3.6	6.8	5	ND	ND
Portsmouth Well	11/12/2021	0.8 J	ND	NA	NA	NA	NA	3.3	3.8	NA	ND	ND	ND	4.6	7.1	6.1	ND	NA
Portsmouth Well	11/16/2021	ND	ND	NA	NA	NA	NA	2.3 J	2.8 J	ND	ND	ND	ND	2.8 J	6.1	4.3	ND	ND
Portsmouth Well	12/14/2021	ND	ND	NA	NA	NA	NA	2.4 J	3.7 J	ND	ND	ND	ND	4.0	8.5	5.5	ND	ND
Portsmouth Well	1/18/2022	ND	ND	NA	NA	NA	NA	2.5 J	2.6 J	ND	ND	ND	ND	2.2 J	5	3.6	ND	ND
Portsmouth Well	2/22/2022	ND	ND	NA	NA	NA	NA	2.4	4.0	ND	ND	ND	ND	4.4	6.5	6.2	ND	ND
Portsmouth Well	3/1/2022	ND	ND	NA	NA	NA	NA	3.1	4.7	NA	ND	ND	ND	5.5	9.1	7.6	ND	NA
Portsmouth Well	3/22/2022	ND	ND	NA	NA	NA	NA	2.3 J	3.4	ND	ND	ND	ND	2.9	8.3	5.1	ND	ND
Portsmouth Well	4/19/2022	ND	ND	NA	NA	NA	NA	1.5 J	3.0	ND	ND	ND	ND	2.9	5.5	4.1	ND	ND
Portsmouth Well	5/25/2022	ND	ND	NA	NA	NA	NA	2.5	2.3	ND	ND	ND	ND	2.1	4.9	3.5	ND	ND
Portsmouth Well	6/10/2022	1.1 J	ND	NA	NA	NA	NA	2.9	4.5	NA	ND	ND	ND	5.8	7.7	8.4	ND	NA
Portsmouth Well	7/19/2022	0.8 J	ND	NA	NA	NA	NA	2.3	2.5	ND	ND	ND	0.98 J	2.6	4.8	4.2	ND	ND
Portsmouth Well	9/1/2022	ND	ND	NA	NA	NA	NA	3.5	4.9	NA	ND	ND	ND	6.0	9.6	8.6	ND	NA
Portsmouth Well	9/21/2022	ND	ND	NA	NA	NA	NA	2.8	2.8	ND	ND	ND	ND	3.2	8.6	4.5	0.4 J	ND
Portsmouth Well	10/26/2022	ND	ND	NA	NA	NA	NA	2.8	3.0	ND	ND	ND	ND	2.8	7.0	4.5	0.5 J	ND
Portsmouth Well	11/10/2022	ND	ND	NA	NA	NA	NA	2.7	3.7	NA	ND	ND	ND	3.8	8.1	5.8	ND	NA
Portsmouth Well	11/15/2022	0.9 J	ND	NA	NA	NA	NA	2.6	4.8	ND	ND	ND	ND	6.2	7.1	8.5	ND	ND
Portsmouth Well	12/20/2022	ND	ND	NA	NA	NA	NA	2.9	5.0	ND	ND	ND	ND	5.9	9.1	7.8	0.6 J	ND

ND = Not detected above Method Detection Limit (MDL)

NA = Not analyzed

J = Estimated value between the Method Detection Limit (MDL) and the Reportable Detection Limit (RDL)

PORTSMOUTH WELL #1
 PFAS SAMPLE RESULTS
 (UNITS: PARTS PER TRILLION (PPT))

SAMPLE LOCATION	NHDES MCL	15	12	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	COLLECTION DATE	PFOS	PFOA	PFPeA	PFTeDA	PFTrDA	PFUnA	PFMPA	PFMBA	PFEESA	NFDHA	4:2 FTS	PFPeS	HFPO-DA	ADONA	11CI-PF3OUds	9CI-PF3ONS
Portsmouth Well	5/20/2014	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	6/18/2014	ND	ND	6.8 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	6/25/2014	ND	ND	3.1 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	6/25/2014	ND	ND	3.5 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	7/2/2014	10 J	ND	6.0 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	7/9/2014	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	7/16/2014	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	7/24/2014	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	7/24/2014	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	8/6/2014	ND	ND	3.2 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	8/21/2014	ND	ND	4.5 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	9/4/2014	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	9/17/2014	4.9 J	ND	3.5 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	10/16/2014	7.3 J	6.2 J	9.0 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	11/12/2014	3.9 J	ND	3.3 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	12/12/2014	3.9 J	ND	5.7 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	1/5/2015	7.4 J	5.3 J	8.3 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	2/4/2015	7.5 J	6.9 J	8.5 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	3/17/2015	7.0 J	ND	6.3 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	3/26/2015	6.8	ND	7.7	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	4/23/2015	5.9 J	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	5/21/2015	7.6 J	ND	3.8 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	6/16/2015	4.5 J	ND	5.3 J	4.9 J	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	7/16/2015	5.0 J	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	8/11/2015	7.0 J	5.1 J	8.9 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	9/9/2015	4.8 J	4.8 J	6.4 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	10/7/2015	7.4 J	7.6 J	6.9 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	11/4/2015	6.4 J	7.0 J	11 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	12/1/2015	7.7 J	6.9 J	5.8 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	1/6/2016	ND	5.6 J	8.2 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	2/2/2016	6.9 J	6.6 J	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	3/1/2016	ND	13 J	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	3/29/2016	4.4 J	5.9 J	9.0 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	4/12/2016	7.2	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	5/26/2016	6.8 J	6.9 J	4.9 J	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	6/23/2016	6.0 J	ND	6.6 J	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	7/19/2016	6.2 J	ND	8.8 J	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	8/2/2016	5.4 J	7.0 J	9.5 J	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	9/13/2016	4.5	5.7 J	5.9	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	11/17/2016	8.2 J	ND	9.2 J	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	1/11/2017	8.4 J	5.9 J	7.6 J	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	2/17/2017	ND	5.3 J	7.2 J	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	3/23/2017	ND	ND	3.2 J	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	3/23/2017	ND	ND	3.2 J	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	4/19/2017	6.0 J	6.2 J	4.4 J	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	6/12/2017	ND	7.2 J	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	7/11/2017	ND	ND	7.1 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

ND = Not detected above Method Detection Limit (MDL)

NA = Not analyzed

J = Estimated value between the Method Detection Limit (MDL) and the Reportable Detection Limit (RDL)

PORTSMOUTH WELL #1
 PFAS SAMPLE RESULTS
 (UNITS: PARTS PER TRILLION (PPT))

SAMPLE LOCATION	NHDES MCL	15	12	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	COLLECTION DATE	PFOS	PFOA	PFPeA	PFTeDA	PFTrDA	PFUnA	PFMPA	PFMBA	PFEESA	NFDHA	4:2 FTS	PFPeS	HFPO-DA	ADONA	11CI-PF3OUds	9CI-PF3ONS
Portsmouth Well	8/2/2017	4.0 J	8.4 J	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	9/15/2017	ND	ND	4.5 J	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	10/19/2017	6.6 J	10.0 J	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	11/14/2017	ND	5.1 J	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	12/8/2017	ND	8.5 J	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	1/9/2018	ND	6.8 J	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	2/6/2018	8.2 J	8.5 J	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	3/6/2018	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	4/23/2018	ND	5.9 J	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	5/16/2018	10.0 J	7.5 J	8.6 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	6/6/2018	ND	3.5 J	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	7/12/2018	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	8/16/2018	ND	6.2 J	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	9/20/2018	8.4 J	5.5 J	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	10/18/2018	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	11/7/2018	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	12/19/2018	ND	3.6 J	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	1/23/2019	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	2/20/2019	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	4/29/2019	4.2	4.4	4.9	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	5/23/2019	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	6/12/2019	ND	ND	5.4 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	7/16/2019	5.8 J	7.5 J	5.7 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	7/31/2019	3.1	4.8	3.7	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	8/14/2019	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	9/17/2019	ND	ND	4.7 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	10/15/2019	3.5	4.4	4.4	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	10/25/2019	3.6	4.3	2.5	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	11/19/2019	2.8	3.9	3.3	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	12/4/2019	3.1	3.7	4.2	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	12/4/2019	3.1	3.7	4.2	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	1/21/2020	2.7	3.5	4.0	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	1/21/2020	2.7	3.5	4.0	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	1/23/2020	4.7	5.5	4.4	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	2/18/2020	3.3	3.9	3.8	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	3/24/2020	5.0	5.2	4.4	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	4/27/2020	4.9	4.8	4.6	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	4/29/2020	2.4	3.3	2.6	0.1 J	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	5/26/2020	4.3	4.5	5.0	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	6/24/2020	4.8	5.2	4.8	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	7/22/2020	3.2	3.8	3.1	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	7/28/2020	6.3	6.1	5.2	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	8/25/2020	5.4	4.7	4.2	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	9/25/2020	4.6	5.1	6.4	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	10/26/2020	5.2	4.7	5.5	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	10/30/2020	4.8	5.1	6.8	NA	NA	ND	ND	ND	ND	ND	ND	0.8 J	ND	ND	ND	ND
Portsmouth Well	11/16/2020	5.6	5.3	6.2	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

ND = Not detected above Method Detection Limit (MDL)

NA = Not analyzed

J = Estimated value between the Method Detection Limit (MDL) and the Reportable Detection Limit (RDL)

PORTSMOUTH WELL #1
 PFAS SAMPLE RESULTS
 (UNITS: PARTS PER TRILLION (PPT))

SAMPLE LOCATION	NHDES MCL	15	12	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	COLLECTION DATE	PFOS	PFOA	PFPeA	PFTeDA	PFTrDA	PFUnA	PFMPA	PFMBA	PFEESA	NFDHA	4:2 FTS	PFPeS	HFPO-DA	ADONA	11CI-PF3OUds	9CI-PF3ONS
Portsmouth Well	12/14/2020	4.2	4.5	5.9	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	1/25/2021	5.0	5.1	5.4	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	1/28/2021	4.9	5.9	8.6	NA	NA	ND	ND	ND	ND	ND	ND	0.4 J	ND	ND	ND	ND
Portsmouth Well	2/5/2021	3.9	3.6 J	3.7	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	3/22/2021	4.8	5.1	6.1 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	4/19/2021	5.0	5.4	4.6	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	4/20/2021	4.7	6.1	6.2	NA	NA	ND	ND	ND	ND	ND	ND	0.7 J	ND	ND	ND	ND
Portsmouth Well	5/24/2021	5.6	5.3	6.3	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	6/22/2021	5.4	5.4	5.1	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	7/20/2021	2.8	3.8	4.4	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	8/3/2021	5.2	6.9	6.2	NA	NA	ND	ND	ND	ND	ND	ND	0.8 J	ND	ND	ND	ND
Portsmouth Well	8/24/2021	3.5	3.8	4.1	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	9/22/2021	3.6	4.4	4.5	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	10/19/2021	4.1	4.5	6.2	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	11/12/2021	5.31	6.8	7.09	NA	NA	ND	ND	ND	ND	ND	ND	0.9 J	ND	ND	ND	ND
Portsmouth Well	11/16/2021	4.3	4.1	5.2	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	12/14/2021	5.1	5.4	6.7	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	1/18/2022	4.9	4.5	4.4	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	2/22/2022	3.9	4.8	8.4	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	3/1/2022	5.6	7.0	9.64	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Portsmouth Well	3/22/2022	3.8	4.2	6	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	4/19/2022	2.6	3.0	5.4	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	5/25/2022	3.7	4.5	3.9	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	6/10/2022	5.3	7.3	10.1	NA	NA	ND	ND	ND	ND	ND	ND	1.0 J	ND	ND	ND	ND
Portsmouth Well	7/19/2022	3.4	3.5	4.6	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	9/1/2022	6.1	7.9	10.8	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Portsmouth Well	9/21/2022	5.5	4.8	5.4	ND	ND	ND	NA	NA	NA	NA	NA	NA	ND	NA	NA	NA
Portsmouth Well	10/26/2022	4.0	5.3	5.0	ND	ND	ND	NA	NA	NA	NA	NA	NA	ND	NA	NA	NA
Portsmouth Well	11/10/2022	5.1	5.6	6.6	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Portsmouth Well	11/15/2022	4.5	6.1	11.0	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Portsmouth Well	12/20/2022	6.2	6.3	10.0	ND	0.4 J	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

ND = Not detected above Method Detection Limit (MDL)

NA = Not analyzed

J = Estimated value between the Method Detection Limit (MDL) and the Reportable Detection Limit (RDL)

COLLINS WELL
 PFAS SAMPLE RESULTS
 (UNITS: PARTS PER TRILLION (PPT))

SAMPLE LOCATION	NHDES MCL	-	-	-	-	-	-	-	-	-	-	-	-	-	18	-	11	-
	COLLECTION DATE	6:2 FTS	8:2 FTS	EtFOSA	EtFOSE	MEFOSA	MEFOSE	PFBS	PFBA	PFDS	PFDA	PFDaA	PFHpS	PFHpA	PFHxS	PFHxA	PFNA	PFOSA
Collins Well	5/16/2014	NA	NA	NA	NA	NA	NA	ND	NA	NA	NA	NA	NA	ND	NA	NA	ND	NA
Collins Well	6/18/2014	NA	NA	NA	NA	NA	NA	ND	ND	ND	ND	ND	NA	ND	ND	ND	ND	ND
Collins Well	6/18/2014	NA	NA	NA	NA	NA	NA	ND	2.8 J	ND	ND	ND	NA	ND	ND	ND	ND	ND
Collins Well	6/25/2014	NA	NA	NA	NA	NA	NA	ND	ND	ND	ND	ND	NA	ND	ND	ND	ND	ND
Collins Well	7/2/2014	NA	NA	NA	NA	NA	NA	ND	5.6 J	ND	ND	ND	NA	ND	ND	ND	ND	ND
Collins Well	7/9/2014	NA	NA	NA	NA	NA	NA	ND	ND	ND	ND	ND	NA	ND	ND	ND	ND	ND
Collins Well	7/16/2014	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.5 J	ND	ND	ND
Collins Well	7/24/2014	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	8/6/2014	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	8/21/2014	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	9/4/2014	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	9/17/2014	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	10/16/2014	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.8 J	ND	ND	ND
Collins Well	11/12/2014	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	12/12/2014	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	1/5/2015	ND	ND	ND	ND	3.2 J	ND	ND	3.5	4.3 J	ND	ND	6.2 J	ND	ND	ND	ND	ND
Collins Well	2/4/2015	ND	ND	9.1 J	ND	ND	ND	ND	3.1 J	ND	ND	ND	ND	ND	3.8 J	ND	ND	ND
Collins Well	3/17/2015	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.4 J	ND	ND	ND	ND	ND
Collins Well	3/26/2015	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	4/23/2015	ND	ND	ND	4.8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.7
Collins Well	5/21/2015	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	6/16/2015	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.3 J	ND	ND	ND	ND	ND	ND	ND
Collins Well	7/16/2015	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	8/11/2015	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	5.4 J	ND	ND	ND	ND	ND	ND
Collins Well	9/9/2015	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	10/7/2015	ND	ND	ND	ND	ND	ND	ND	6.3 J	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	11/4/2015	ND	ND	ND	8.0 J	ND	ND	ND	ND	ND	ND	ND	ND	ND	6.0 J	ND	ND	ND
Collins Well	12/1/2015	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	6.6 J	ND	ND	ND
Collins Well	1/6/2016	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	5.7	ND	ND	ND
Collins Well	2/2/2016	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.1	7.0	ND	ND
Collins Well	3/1/2016	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	8.4 J	ND	ND	ND
Collins Well	3/29/2016	ND	ND	ND	ND	ND	ND	5.0 J	7.7 J	ND	ND	ND	ND	ND	5.1	ND	ND	ND
Collins Well	4/12/2016	ND	ND	NA	NA	NA	NA	ND	ND	NA	NA	NA	ND	ND	5.5	7.3	ND	ND
Collins Well	6/23/2016	ND	ND	NA	NA	NA	NA	3.5 J	ND	NA	NA	NA	ND	ND	4.2 J	5.0 J	ND	ND
Collins Well	7/19/2016	ND	ND	NA	NA	NA	NA	3.4 J	ND	NA	NA	NA	ND	ND	5.8 J	ND	ND	ND
Collins Well	8/2/2016	ND	ND	NA	NA	NA	NA	7.5 J	ND	NA	NA	NA	ND	ND	5.4 J	5.7 J	ND	ND
Collins Well	9/13/2016	ND	ND	NA	NA	NA	NA	7.9	ND	NA	NA	NA	ND	ND	ND	ND	ND	ND
Collins Well	10/19/2016	ND	ND	NA	NA	NA	NA	10 J	ND	NA	NA	NA	ND	ND	5.4 J	ND	ND	ND
Collins Well	11/17/2016	ND	ND	NA	NA	NA	NA	16 J	ND	NA	NA	NA	ND	ND	ND	ND	ND	ND
Collins Well	12/14/2016	ND	ND	NA	NA	NA	NA	15 J	ND	NA	NA	NA	ND	ND	6.0 J	ND	ND	ND
Collins Well	1/11/2017	ND	ND	NA	NA	NA	NA	20 J	ND	NA	NA	NA	ND	ND	8.2 J	9.3 J	ND	ND
Collins Well	2/17/2017	ND	ND	NA	NA	NA	NA	13 J	ND	NA	NA	NA	ND	ND	ND	ND	ND	ND
Collins Well	3/23/2017	ND	ND	NA	NA	NA	NA	8.9 J	ND	NA	NA	NA	ND	ND	ND	ND	ND	ND
Collins Well	4/19/2017	ND	ND	NA	NA	NA	NA	7.9 J	ND	NA	NA	NA	ND	ND	4.2 J	ND	ND	ND
Collins Well	6/12/2017	ND	ND	ND	ND	ND	ND	10 J	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	7/11/2017	ND	ND	ND	ND	ND	ND	9.4 J	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	8/2/2017	ND	ND	ND	ND	ND	ND	11 J	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

ND = Not detected above Method Detection Limit (MDL)

NA = Not analyzed

J = Estimated value between the Method Detection Limit (MDL) and the Reportable Detection Limit (RDL)

COLLINS WELL
 PFAS SAMPLE RESULTS
 (UNITS: PARTS PER TRILLION (PPT))

SAMPLE LOCATION	NHDES MCL	-	-	-	-	-	-	-	-	-	-	-	-	-	18	-	11	-
	COLLECTION DATE	6:2 FTS	8:2 FTS	EtFOSA	EtFOSE	MEFOSA	MEFOSE	PFBS	PFBA	PFDS	PFDA	PFDaA	PFHpS	PFHpA	PFHxS	PFHxA	PFNA	PFOSA
Collins Well	9/15/2017	ND	ND	NA	NA	NA	NA	12 J	ND	NA	NA	NA	ND	ND	ND	ND	ND	ND
Collins Well	10/19/2017	ND	ND	ND	ND	ND	ND	20 J	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	11/14/2017	ND	ND	ND	ND	ND	ND	14 J	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	12/8/2017	ND	ND	ND	ND	ND	ND	19 J	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	1/9/2018	ND	ND	ND	ND	ND	ND	21	ND	ND	ND	ND	ND	ND	ND	4.0 J	ND	ND
Collins Well	2/6/2018	ND	ND	ND	ND	ND	ND	22	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.0 J
Collins Well	3/6/2018	ND	ND	ND	ND	ND	ND	18 J	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	4/23/2018	ND	ND	ND	ND	ND	ND	20 J	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	5/16/2018	ND	ND	ND	ND	ND	ND	19 J	7.4 J	ND	ND	ND	ND	ND	ND	5.9 J	ND	ND
Collins Well	6/6/2018	ND	ND	ND	ND	ND	ND	21 J	9.1 J	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	7/12/2018	ND	ND	ND	ND	ND	ND	11 J	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	8/16/2018	ND	ND	ND	ND	ND	ND	19 J	7.3 J	ND	ND	ND	ND	ND	ND	5.6 J	ND	ND
Collins Well	9/20/2018	ND	ND	ND	ND	ND	ND	25	5.6 J	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	10/18/2018	ND	ND	ND	ND	ND	ND	22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	11/7/2018	ND	ND	NA	NA	NA	NA	12 J	ND	NA	NA	NA	ND	ND	ND	ND	ND	ND
Collins Well	12/19/2018	ND	ND	ND	ND	ND	ND	19 J	7.0 J	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	1/23/2019	ND	ND	ND	ND	ND	ND	13 J	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	2/20/2019	ND	ND	ND	ND	ND	ND	12 J	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	3/20/2019	ND	ND	ND	ND	ND	ND	8.4 J	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	4/4/2019	ND	ND	ND	ND	ND	ND	12 J	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	4/29/2019	0.8 J	ND	NA	NA	NA	NA	12	3.0	ND	ND	ND	ND	1.2 J	2.2	1.6 J	0.7 J	ND
Collins Well	5/23/2019	ND	ND	ND	ND	ND	ND	11 J	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	6/12/2019	ND	ND	ND	ND	ND	ND	15 J	8.1 J	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	7/16/2019	ND	ND	ND	ND	ND	ND	14 J	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	7/31/2019	ND	ND	NA	NA	NA	NA	14	3.6	ND	ND	ND	ND	1.1 J	2.3	1.9 J	ND	ND
Collins Well	8/14/2019	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	9/17/2019	ND	ND	ND	ND	ND	ND	16 J	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	10/15/2019	ND	ND	NA	NA	NA	NA	14	3.4	ND	ND	ND	ND	1.0 J	2.1 J	1.5 J	ND	ND
Collins Well	10/25/2019	ND	ND	ND	NA	ND	NA	17	3.5 J	ND	ND	ND	ND	0.8 J	2.1	1.3	ND	ND
Collins Well	11/19/2019	ND	ND	NA	NA	NA	NA	15	3.0	ND	ND	ND	ND	0.5 J	1.6 J	1.1 J	ND	ND
Collins Well	12/4/2019	ND	ND	NA	NA	NA	NA	15	3.0	ND	ND	ND	ND	0.6 J	2.0 J	1.0 J	ND	ND
Collins Well	12/4/2019	ND	ND	NA	NA	NA	NA	15	3.0	ND	ND	ND	ND	0.6 J	2.0 J	1.0 J	ND	ND
Collins Well	1/21/2020	ND	ND	NA	NA	NA	NA	16	3.0	ND	ND	ND	ND	ND	1.0 J	0.6 J	ND	ND
Collins Well	1/21/2020	ND	ND	NA	NA	NA	NA	16	3.0	ND	ND	ND	ND	ND	1.0 J	0.6 J	ND	ND
Collins Well	1/23/2020	ND	ND	0.8 J	NA	ND	NA	17	3.6 J	ND	ND	ND	ND	0.9 J	2.0 J	1.6 J	ND	ND
Collins Well	2/18/2020	ND	ND	NA	NA	NA	NA	14	3.1	ND	ND	ND	ND	0.5 J	1.5 J	0.9 J	ND	ND
Collins Well	3/24/2020	ND	ND	NA	NA	NA	NA	19.1	5.7 J	ND	ND	ND	ND	ND	2.0 J	1.1 J	ND	ND
Collins Well	4/27/2020	ND	ND	NA	NA	NA	NA	14.3	5.2 J	ND	ND	ND	ND	ND	1.2 J	ND	ND	ND
Collins Well	4/29/2020	ND	ND	NA	NA	NA	NA	12.0	4.3	ND	ND	ND	ND	0.5	1.4 J	0.8	0.2 J	ND
Collins Well	5/26/2020	ND	ND	NA	NA	NA	NA	12.6	5.2 J	ND	ND	ND	ND	1.1 J	1.7 J	1.3 J	ND	ND
Collins Well	6/24/2020	ND	ND	NA	NA	NA	NA	13.3	5.0 J	ND	ND	ND	ND	1.7 J	2.3 J	2.2 J	ND	ND
Collins Well	7/22/2020	NA	NA	NA	NA	NA	NA	11.0	3.6	ND	ND	ND	ND	0.9 J	1.8 J	1.6 J	ND	ND
Collins Well	7/28/2020	ND	ND	NA	NA	NA	NA	16.5	4.7 J	ND	ND	ND	ND	1.5 J	2.8 J	2.5 J	ND	ND
Collins Well	8/25/2020	ND	ND	NA	NA	NA	NA	14.3	5.0 J	ND	ND	ND	ND	1.3 J	2.4 J	1.9 J	ND	ND
Collins Well	9/25/2020	ND	ND	NA	NA	NA	NA	16.4	4.8 J	ND	ND	ND	ND	1.2 J	2.7 J	1.8 J	ND	ND
Collins Well	10/26/2020	ND	ND	NA	NA	NA	NA	14.9	3.7	ND	ND	ND	ND	ND	2.6	1.4	ND	ND
Collins Well	10/30/2020	ND	ND	NA	NA	NA	NA	18.2	4.9	NA	ND	ND	ND	1.3 J	2.7	2.1	ND	NA

ND = Not detected above Method Detection Limit (MDL)

NA = Not analyzed

J = Estimated value between the Method Detection Limit (MDL) and the Reportable Detection Limit (RDL)

COLLINS WELL
 PFAS SAMPLE RESULTS
 (UNITS: PARTS PER TRILLION (PPT))

SAMPLE LOCATION	NHDES MCL	-	-	-	-	-	-	-	-	-	-	-	-	18	-	11	-	
	COLLECTION DATE	6:2 FTS	8:2 FTS	EtFOSA	EtFOSE	MEFOSA	MEFOSE	PFBS	PFBA	PFDS	PFDA	PFDaA	PFHpS	PFHpA	PFHxS	PFHxA	PFNA	PFOSA
Collins Well	11/16/2020	ND	ND	NA	NA	NA	NA	15.0	4.8 J	ND	ND	ND	ND	1.0 J	2.7 J	1.8 J	ND	ND
Collins Well	1/25/2021	ND	ND	NA	NA	NA	NA	18.1	5.6 J	ND	ND	ND	ND	1.6 J	2.3 J	3.4 J	ND	ND
Collins Well	1/28/2021	ND	ND	NA	NA	NA	NA	20.5	4.6	NA	ND	ND	ND	1.2 J	2.2	2.7	0.6 J	NA
Collins Well	2/5/2021	3.0 J	ND	NA	NA	NA	NA	14.2	2.6 J	ND	ND	ND	ND	ND	2.0 J	1.5 J	ND	ND
Collins Well	3/22/2021	ND	ND	NA	NA	NA	NA	18.7	3.1 J	ND	ND	ND	ND	ND	2.2 J	0.9 J	ND	ND
Collins Well	4/19/2021	ND	ND	NA	NA	NA	NA	13.3	4.1 J	ND	ND	ND	ND	ND	2.1 J	1.0 J	ND	ND
Collins Well	4/20/2021	ND	ND	NA	NA	NA	NA	16.4	4.4	NA	ND	ND	ND	0.6 J	2.0	1.1 J	ND	NA
Collins Well	5/24/2021	ND	ND	NA	NA	NA	NA	13.0	6.5 J	ND	ND	ND	ND	0.9 J	2.7 J	1.1 J	ND	ND
Collins Well	6/22/2021	ND	ND	NA	NA	NA	NA	13.4	5.9 J	ND	ND	ND	ND	1.5 J	2.6 J	2.0 J	ND	ND
Collins Well	7/20/2021	ND	ND	NA	NA	NA	NA	14.0	6.0	ND	ND	ND	ND	1.5 J	2.3	2.1	ND	ND
Collins Well	8/3/2021	ND	ND	NA	NA	NA	NA	16.4	6.1	NA	ND	ND	ND	1.6 J	2.6	2.9	0.6 J	NA
Collins Well	8/24/2021	ND	ND	NA	NA	NA	NA	12.0	3.3	ND	ND	ND	ND	0.7 J	1.9 J	1.2 J	ND	ND
Collins Well	9/22/2021	ND	ND	NA	NA	NA	NA	13	4.8	ND	ND	ND	ND	1.3 J	2.5	2.6	ND	ND
Collins Well	10/19/2021	ND	ND	NA	NA	NA	NA	15	5.9	ND	ND	ND	ND	1.3 J	2.1	3	ND	ND
Collins Well	11/12/2021	ND	ND	NA	NA	NA	NA	17.3	4.9	NA	ND	ND	ND	0.9 J	2.0	1.7 J	ND	NA
Collins Well	11/16/2021	ND	ND	NA	NA	NA	NA	15.4	4.4 J	ND	ND	ND	ND	ND	2.0 J	1.8 J	ND	ND
Collins Well	12/14/2021	ND	ND	NA	NA	NA	NA	14.5	5.1 J	ND	ND	ND	ND	1.1 J	1.5 J	2.6 J	ND	ND
Collins Well	1/18/2022	ND	ND	NA	NA	NA	NA	11.3	2.9 J	ND	ND	ND	ND	ND	1.4 J	ND	ND	ND
Collins Well	2/22/2022	ND	ND	NA	NA	NA	NA	13.0	2.4	ND	ND	ND	ND	ND	0.98 J	ND	ND	ND
Collins Well	3/1/2022	ND	ND	NA	NA	NA	NA	20.4	3.5	NA	ND	ND	ND	ND	ND	ND	ND	NA
Collins Well	3/22/2022	ND	ND	NA	NA	NA	NA	16.0	3.9	ND	ND	ND	ND	ND	1.5 J	ND	ND	ND
Collins Well	4/19/2022	ND	ND	NA	NA	NA	NA	11.0	3.1	ND	ND	ND	ND	0.5 J	1.5 J	0.8 J	ND	ND
Collins Well	5/25/2022	ND	ND	NA	NA	NA	NA	9.0	4.8	ND	ND	ND	ND	0.6 J	1.8 J	1.0 J	ND	ND
Collins Well	6/10/2022	ND	ND	NA	NA	NA	NA	13.4	9.5	NA	ND	ND	ND	1.8 J	3.2	2.4	ND	NA
Collins Well	6/23/2022	ND	ND	NA	NA	NA	NA	11.0	6.0	ND	ND	ND	ND	1.8 J	3.0	2.3	ND	ND
Collins Well	9/1/2022	ND	ND	NA	NA	NA	NA	13.0	5.7	NA	ND	ND	ND	ND	3.0	3.3	ND	NA
Collins Well	9/21/2022	ND	ND	NA	NA	NA	NA	9.8	3.9	ND	ND	ND	ND	1.1 J	2.0	1.9 J	0.4 J	ND
Collins Well	11/10/2022	ND	ND	NA	NA	NA	NA	5.2	2.1	NA	ND	ND	ND	ND	ND	ND	ND	NA
Collins Well	11/15/2022	ND	ND	NA	NA	NA	NA	9.0	2.9	ND	ND	ND	ND	0.8 J	2.3	1.6 J	ND	ND

ND = Not detected above Method Detection Limit (MDL)

NA = Not analyzed

J = Estimated value between the Method Detection Limit (MDL) and the Reportable Detection Limit (RDL)

COLLINS WELL
 PFAS SAMPLE RESULTS
 (UNITS: PARTS PER TRILLION (PPT))

SAMPLE LOCATION	NHDES MCL	15	12	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	COLLECTION DATE	PFOS	PFOA	PFPeA	PFTeDA	PFTrDA	PFUnA	PFMPA	PFMBA	PFEESA	NFDHA	4:2 FTS	PFPeS	HFPO-DA	ADONA	11CI-PF3OUds	9CI-PF3ONS
Collins Well	5/16/2014	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	6/18/2014	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	6/18/2014	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	6/25/2014	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	7/2/2014	7.2 J	ND	3.2 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	7/9/2014	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	7/16/2014	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	7/24/2014	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	8/6/2014	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	8/21/2014	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	9/4/2014	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	9/17/2014	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	10/16/2014	4.8 J	ND	4.4 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	11/12/2014	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	12/12/2014	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	1/5/2015	4.7 J	ND	3.5 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	2/4/2015	ND	ND	ND	ND	ND	5.4 J	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	3/17/2015	5.4 J	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	3/26/2015	4.7	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	4/23/2015	4.1 J	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	5/21/2015	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	6/16/2015	ND	ND	ND	5.2 J	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	7/16/2015	4.0 J	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	8/11/2015	6.3 J	ND	7.7 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	9/9/2015	4.4 J	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	10/7/2015	7.4 J	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	11/4/2015	7.3 J	ND	ND	9.4 J	ND	5.2 J	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	12/1/2015	7.6 J	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	1/6/2016	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	2/2/2016	6.7 J	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	3/1/2016	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	3/29/2016	3.4 J	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	4/12/2016	5.8	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	6/23/2016	5.4 J	5.5 J	6.9 J	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	7/19/2016	6.1 J	ND	5.5 J	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	8/2/2016	5.2 J	7.1 J	8.5 J	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	9/13/2016	4.7	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	10/19/2016	5.1 J	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	11/17/2016	6.1 J	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	12/14/2016	6.7 J	ND	4.7 J	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	1/11/2017	7.1 J	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	2/17/2017	6.8 J	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	3/23/2017	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	4/19/2017	5.6 J	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	6/12/2017	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	7/11/2017	ND	ND	6.9 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	8/2/2017	4.2 J	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

ND = Not detected above Method Detection Limit (MDL)

NA = Not analyzed

J = Estimated value between the Method Detection Limit (MDL) and the Reportable Detection Limit (RDL)

COLLINS WELL
 PFAS SAMPLE RESULTS
 (UNITS: PARTS PER TRILLION (PPT))

SAMPLE LOCATION	NHDES MCL	15	12	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	COLLECTION DATE	PFOS	PFOA	PFPeA	PFTeDA	PFTrDA	PFUnA	PFMPA	PFMBA	PFEESA	NFDHA	4:2 FTS	PFPeS	HFPO-DA	ADONA	11CI-PF3OUds	9CI-PF3ONS
Collins Well	9/15/2017	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	10/19/2017	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	11/14/2017	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	12/8/2017	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	1/9/2018	9.5 J	8.5 J	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	2/6/2018	ND	5.9 J	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	3/6/2018	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	4/23/2018	ND	4.1 J	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	5/16/2018	7.9 J	6.7 J	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	6/6/2018	ND	7.2 J	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	7/12/2018	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	8/16/2018	ND	4.9 J	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	9/20/2018	6.6 J	5.2 J	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	10/18/2018	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	11/7/2018	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	12/19/2018	ND	3.9 J	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	1/23/2019	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	2/20/2019	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	3/20/2019	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	4/4/2019	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	4/29/2019	2.6	2.4	1.8 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	5/23/2019	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	6/12/2019	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	7/16/2019	5.7 J	7.5 J	5.2 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	7/31/2019	3.4	4.2	2.5	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	8/14/2019	ND	ND	6.0 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	9/17/2019	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	10/15/2019	2.9	2.5	1.8 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	10/25/2019	2.8	2.4	3.5	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	11/19/2019	1.9 J	2.1	1.3 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	12/4/2019	2.7	2.1	1.2 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	12/4/2019	2.7	2.1	1.2 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	1/21/2020	1.9 J	1.3 J	1.0 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	1/21/2020	1.9 J	1.3 J	1.0 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	1/23/2020	3.2	2.7	1.3 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	2/18/2020	2.3	1.8 J	1.2 J	0.7 J	0.5 J	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	3/24/2020	2.9 J	2.2 J	1.5 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	4/27/2020	2.2 J	1.9 J	1.4 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	4/29/2020	1.3 J	1.8	ND	0.1 J	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	5/26/2020	3.3 J	3.3 J	2.4 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	6/24/2020	4.9	5.1	3.5 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	7/22/2020	3.1	3.3	2.1	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	7/28/2020	5.0	4.8	3.5 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	8/25/2020	4.5	4.1	3.2 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	9/25/2020	5.1	3.7 J	2.9 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	10/26/2020	5.3	3.2	2.1	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	10/30/2020	4.2	3.2	2.8	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

ND = Not detected above Method Detection Limit (MDL)

NA = Not analyzed

J = Estimated value between the Method Detection Limit (MDL) and the Reportable Detection Limit (RDL)

COLLINS WELL
 PFAS SAMPLE RESULTS
 (UNITS: PARTS PER TRILLION (PPT))

SAMPLE LOCATION	NHDES MCL	15	12	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	COLLECTION DATE	PFOS	PFOA	PFPeA	PFTeDA	PFTrDA	PFUnA	PFMPA	PFMBA	PFEESA	NFDHA	4:2 FTS	PFPeS	HFPO-DA	ADONA	11CI-PF3OUds	9CI-PF3ONS
Collins Well	11/16/2020	4.5	3.3 J	2.5 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	1/25/2021	3.2 J	3.2 J	6.0	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	1/28/2021	2.9	4.5	3.7	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	2/5/2021	3.7	2.0 J	1.8 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	3/22/2021	2.9 J	1.6 J	1.2 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	4/19/2021	3.9	2.2 J	1.4 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	4/20/2021	3.2	2.5	1.3 J	NA	NA	ND	ND	ND	ND	NA	ND	ND	ND	ND	ND	ND
Collins Well	5/24/2021	4.6	2.9 J	1.9 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	6/22/2021	5.3	5.2	3.3 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	7/20/2021	3.5	3.9	3.3	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	8/3/2021	5.1	5.8	4.2	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	8/24/2021	3	2.6	2.1	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	9/22/2021	4.5	4	3.9	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	10/19/2021	4.1	3.6	5	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	11/12/2021	4.6	3.4	2.4	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	11/16/2021	4.0	2.7 J	2.8 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	12/14/2021	3.9	3.1 J	3.9	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	1/18/2022	1.9 J	1.4 J	1.1 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	2/22/2022	1.3 J	1.1 J	1 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	3/1/2022	ND	ND	ND	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	3/22/2022	1.4 J	1.3 J	1.0 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	4/19/2022	1.7 J	1.5 J	1.0 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	5/25/2022	2.5	2.0 J	1.3 J	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	6/10/2022	3.9	5.2	3.6	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	6/23/2022	3.8	4.3	2.9	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Collins Well	9/1/2022	6.3	6.3	4.2	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	9/21/2022	4.7	3.3	2.7	ND	ND	ND	NA	NA	NA	NA	NA	NA	ND	NA	NA	NA
Collins Well	11/10/2022	3.4	2.3	ND	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Collins Well	11/15/2022	3.7	2.4	2.0	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

ND = Not detected above Method Detection Limit (MDL)
 NA = Not analyzed
 J = Estimated value between the Method Detection Limit (MDL) and the Reportable Detection Limit (RDL)

PEASE WATER TREATMENT FACILITY
TREATED WATER
PFAS SAMPLE RESULTS
(UNITS: PARTS PER TRILLION (PPT))

NHDES MCL		-	-	-	-	-	-	-	-	-	-	-	-	-	18	-	11	-
SAMPLE LOCATION	COLLECTION DATE	6:2 FTS	8:2 FTS	EtFOSA	EtFOSE	MEFOSA	MEFOSE	PFBS	PFBA	PFDS	PFDA	PFDoA	PFHpS	PFHpA	PFHxS	PFHxA	PFNA	PFOSA
Pease WTP	10/25/2019	ND	ND	ND	NA	ND	NA	ND	8.6	ND	ND	ND	ND	ND	ND	0.9 J	ND	ND
Pease WTP	1/23/2020	ND	ND	ND	NA	ND	NA	ND	1.2 J	ND	ND	ND	ND	ND	ND	0.4 J	ND	ND
Pease WTP	4/29/2020	ND	ND	NA	NA	NA	NA	ND	ND	ND	0.21 J	ND	ND	ND	ND	0.3 J	ND	ND
Pease WTP	7/22/2020	NA	NA	NA	NA	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Pease WTP	10/30/2020	ND	ND	NA	NA	NA	NA	ND	12	NA	ND	ND	ND	ND	ND	0.5 J	ND	NA
Pease WTP	1/28/2021	ND	ND	NA	NA	NA	NA	ND	13	NA	ND	ND	ND	ND	0.4 J	0.8 J	ND	NA
Pease WTP	5/12/2021	ND	ND	NA	NA	NA	NA	ND	ND	NA	ND	ND	ND	ND	ND	ND	ND	NA
Pease WTP	8/5/2021	0.842 J	ND	NA	NA	NA	NA	ND	ND	NA	ND	ND	ND	ND	ND	ND	ND	NA
Pease WTP	11/17/2021	ND	ND	NA	NA	NA	NA	ND	ND	NA	ND	ND	ND	ND	ND	ND	ND	NA
Pease WTP	2/10/2022	ND	ND	NA	NA	NA	NA	ND	3.8	NA	ND	ND	ND	ND	ND	ND	ND	NA
Pease WTP	5/18/2022	ND	ND	NA	NA	NA	NA	ND	13	NA	ND	ND	ND	ND	ND	ND	ND	NA
Pease WTP	8/16/2022	ND	ND	NA	NA	NA	NA	ND	17	NA	ND	ND	ND	ND	ND	ND	ND	NA
Pease WTP	11/16/2022	ND	ND	NA	NA	NA	NA	ND	30	NA	ND	ND	ND	ND	ND	ND	ND	NA
Pease WTP	12/14/2022	ND	ND	NA	NA	NA	NA	ND	30	NA	ND	ND	ND	ND	ND	ND	ND	NA

ND = Not detected above Method Detection Limit (MDL)

NA = Not analyzed

J = Estimated value between the Method Detection Limit (MDL) and the Reportable Detection Limit (RDL)

PEASE WATER TREATMENT FACILITY
TREATED WATER
PFAS SAMPLE RESULTS
(UNITS: PARTS PER TRILLION (PPT))

	NHDES MCL	15	12	-	-	-	-	-	-	-	-	-	-	-	-	-	-
SAMPLE LOCATION	COLLECTION DATE	PFOS	PFOA	PFPeA	PFTeDA	PFTrDA	PFUnA	PFMPA	PFMBA	PFEESA	NFDHA	4:2 FTS	PFPeS	HFPO-DA	ADONA	11CI-PF3OUdS	9CI-PF3ONS
Pease WTP	10/25/2019	ND	ND	10.0	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Pease WTP	1/23/2020	ND	0.4 J	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Pease WTP	4/29/2020	ND	0.3 J	ND	0.1 J	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Pease WTP	7/22/2020	ND	ND	ND	ND	ND	ND	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Pease WTP	10/30/2020	ND	ND	3.0	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Pease WTP	1/28/2021	ND	0.3 J	14.0	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Pease WTP	5/12/2021	ND	ND	ND	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Pease WTP	8/5/2021	ND	ND	ND	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Pease WTP	11/17/2021	ND	ND	ND	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Pease WTP	2/10/2022	ND	ND	ND	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Pease WTP	5/18/2022	ND	ND	ND	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Pease WTP	8/16/2022	ND	ND	ND	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Pease WTP	11/16/2022	ND	ND	ND	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Pease WTP	12/14/2022	ND	ND	2.9	NA	NA	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

ND = Not detected above Method Detection Limit (MDL)

NA = Not analyzed

J = Estimated value between the Method Detection Limit (MDL) and the Reportable Detection Limit (RDL)